

Panel Details

Project : SA Tourism [REDACTED]

Page 1

Panel : 1 Name : SA TOURISM [REDACTED]

Type : ZP3 EN54 2 Loop/128 Zone

Installation Date : 20/06/2019

Serial No :

S/W Number : 71910

Software Version : 3.12

Checksum : 51C3

Language : English

| Passwords : | User Name | Password | Access Level |
|-------------|-----------|----------|--------------|
| | Master | 2000 | 4 |

Installed Devices :

Line : 1 Devices : 59 Spares : 0 Available : 68

| Device Type | Quantity |
|-------------------------------|----------|
| Optical Smoke ZP730 ZP730 | 48 |
| Callpoint ZP785 ZP785 | 5 |
| Address Relay ZP750/A51 ZP750 | 1 |
| Line Sounder ZP755 ZP755 | 5 |

Line : 2 Devices : 79 Spares : 0 Available : 48

| Device Type | Quantity |
|---------------------------|----------|
| Optical Smoke ZP730 ZP730 | 67 |
| Callpoint ZP785 ZP785 | 5 |
| Line Sounder ZP754 ZP754 | 1 |
| Line Sounder ZP755 ZP755 | 6 |

Installed Devices Totals : Devices : 138 Spares : 0 Available : 116

Installed Hardware :

| Type | Group | Addr | S/W Ver | Comments |
|-------------|------------|------|---------|---|
| ZP3-RDUB1 | Peripheral | 256 | 1.02 | Remote Display Unit 1 (RDU) |
| ZP3-DISPLAY | Peripheral | 384 | 3.00 | Local Display Board (Local) |
| ZP3AB-SCB-D | Peripheral | 386 | 1.01 | Serial Control Bus Driver Board (Local) |
| LINE-DRIVER | Peripheral | 387 | 3.05 | Main Board Line Driver PIC (Local) |

Global Settings

Project : SA Tourism [REDACTED]

Page 1

Panel : 1

Name : SA TOURISM [REDACTED]

Type : ZP3 EN54 2 Loop/128 Zone

Configuration

Network Mode: **Standalone**
 Panel Mode: **Standard**
 Printer Type: **None**
 Panel Standard: **EN54-2006**

Day/Night Switchover: **Man Day/Night**

Level 4 Operations

Allow Local Programming: **Enabled**
 Mains Monitor: **Enabled**
 Battery Monitor: **Enabled**
 External Mains Monitor: **Disabled**
 External Battery Monitor: **Disabled**
 Display Board Type: **0**
 Main Board Type: **0**
 Clock Set Access Level: **2**
 Panel Language: **English**
 Display Character Set: **English**
 Site ID:

Global Parameters

AVF Faults: **Disabled**
 Address Group Verify: **Disabled**
 Service Alarm Mode: **Enabled**
 Update Time via Network: **Enabled**
 Display Event Time: **Enabled**
 Partial Short Check: **Disabled**
 Common Fire Relay: **Normal**
 Common Fault Relay: **Normal**
 Silence Disable Delay Time: **0**
 Maximum Number of RDUs: **1**
 Maximum Isolators on Line 1: **16**
 Maximum Isolators on Line 2: **16**
 Maximum Isolators on Line 3: **0**
 Maximum Isolators on Line 4: **0**
 Flash LED on Healthy Det.: **Disabled**
 Control Key Access Level: **1**
 Zone LEDs Operation: **Linked**
 Alarm Relay 1 & 2 Operation: **Linked**
 Alarm Relay 3 & 4 Operation: **Linked**
 Fire Co-Incidence Enable: **Disabled**

Panel Keys

Accept: **Free**
 Reset: **Free**
 Silence Alarms: **Level 2**
 Sound Alarms: **Level 2**
 Restore Disabled Alarms: **Level 2**

Remote Manned Centre Options

Fire Relay Cancel: **On Reset**
 Fire Relay Disable: **Enabled**
 Fault Relay Disable: **Enabled**

Disables

Alarm Relay 1 & 2 Disable: **Disabled**
 Alarm Relay 3 & 4 Disable: **Disabled**
 Common Fire Relay Disable: **Disabled**
 Common Fault Relay Disable: **Disabled**
 Restore Disabled Alarms Disable: **Disabled**

Communications Settings

| | Protocol | Baud | Parity | Bits | Stops |
|----------|--------------|-------|--------|------|-------|
| Z-PORT1: | ZCP3/Planner | 9600 | Even | 8 | 1 |
| Z-PORT2: | Stand Alone | 19200 | Even | 8 | 1 |
| Z-PORT3: | None | 19200 | Even | 8 | 1 |
| Z-PORT4: | None | 19200 | Even | 8 | 1 |

RDU Settings

| RDU Number | Poll | Reset Panel | Sound Alarms | Silence Alarms | Accept Alarms | Restore Disables |
|------------|-------|-------------|--------------|----------------|---------------|------------------|
| 1 | False | By Code | By Code | By Code | By Code | By Code |

SECRET

SECRET

○

○

SECRET

SECRET

Zone Messages

Project : SA Tourism

Page 1

Panel :1 Name :SA TOURISM

Type :ZP3 EN54 2 Loop/128 Zone

| Zone | Zone Message | Device Count |
|------|---------------------------|--------------|
| 1 | Security Guard House | 1 |
| 2 | Basement Parking | 24 |
| 3 | Basement Parking | 27 |
| 4 | Ground Floor SE0 & SW0 | 26 |
| 5 | Ground Floor East | 18 |
| 6 | First Floor NE1 & NW1 | 17 |
| 7 | First Floor SE1 & SW1 | 18 |
| 8 | | 0 |
| 9 | | 0 |
| 10 | BGU Trigger Zone Sounders | 1 |
| 11 | | 0 |
| 12 | | 0 |
| 13 | | 0 |
| 14 | | 0 |
| 15 | | 0 |
| 16 | | 0 |
| 17 | | 0 |
| 18 | | 0 |
| 19 | | 0 |
| 20 | | 0 |
| 21 | | 0 |
| 22 | | 0 |
| 23 | | 0 |
| 24 | | 0 |
| 25 | | 0 |
| 26 | | 0 |
| 27 | | 0 |
| 28 | | 0 |
| 29 | | 0 |
| 30 | | 0 |
| 31 | | 0 |
| 32 | | 0 |
| 33 | | 0 |
| 34 | | 0 |
| 35 | | 0 |
| 36 | | 0 |
| 37 | | 0 |
| 38 | | 0 |
| 39 | | 0 |
| 40 | | 0 |
| 41 | | 0 |
| 42 | | 0 |
| 43 | | 0 |
| 44 | | 0 |
| 45 | | 0 |
| 46 | | 0 |
| 47 | | 0 |
| 48 | | 0 |
| 49 | | 0 |
| 50 | | 0 |
| 51 | | 0 |
| 52 | | 0 |
| 53 | | 0 |
| 54 | | 0 |
| 55 | | 0 |
| 56 | | 0 |
| 57 | | 0 |
| 58 | | 0 |
| 59 | | 0 |

Zone Messages

Project : SA Tourism

Panel : 1 (continued from page 1)

| Zone | Zone Message | Device Count |
|------|--------------|--------------|
| 60 | | 0 |
| 61 | | 0 |
| 62 | | 0 |
| 63 | | 0 |
| 64 | | 0 |
| 65 | | 0 |
| 66 | | 0 |
| 67 | | 0 |
| 68 | | 0 |
| 69 | | 0 |
| 70 | | 0 |
| 71 | | 0 |
| 72 | | 0 |
| 73 | | 0 |
| 74 | | 0 |
| 75 | | 0 |
| 76 | | 0 |
| 77 | | 0 |
| 78 | | 0 |
| 79 | | 0 |
| 80 | | 0 |
| 81 | | 0 |
| 82 | | 0 |
| 83 | | 0 |
| 84 | | 0 |
| 85 | | 0 |
| 86 | | 0 |
| 87 | | 0 |
| 88 | | 0 |
| 89 | | 0 |
| 90 | | 0 |
| 91 | | 0 |
| 92 | | 0 |
| 93 | | 0 |
| 94 | | 0 |
| 95 | | 0 |
| 96 | | 0 |
| 97 | | 0 |
| 98 | | 0 |
| 99 | | 0 |
| 100 | | 0 |
| 101 | | 0 |
| 102 | | 0 |
| 103 | | 0 |
| 104 | | 0 |
| 105 | | 0 |
| 106 | | 0 |
| 107 | | 0 |
| 108 | | 0 |
| 109 | | 0 |
| 110 | | 0 |
| 111 | | 0 |
| 112 | | 0 |
| 113 | | 0 |
| 114 | | 0 |
| 115 | | 0 |
| 116 | | 0 |
| 117 | | 0 |
| 118 | | 0 |
| 119 | | 0 |

Device Details

Project : SA Tourism

Panel: 1 Name: SA TOURISM

Type : ZP3 ENS4 2 Loop/128 Zone

Panel: 1 Line: 1

| Addr | Device Type | Zone | Device Message | Sensitivity | Sensitivity | Disable (Prt) | Disable (Sec) | Base Sounder | AVF | Self Test | Radio Sndr Group |
|------|-------------------------|------|----------------------------------|-------------|-------------|---------------|---------------|--------------|-----|-----------|------------------|
| 1001 | Optical Smoke ZP730 | 1 | Guard House Entrance | Standard | | Enabled | | No | Off | No | |
| 1002 | Optical Smoke ZP730 | 2 | Parking area Bay 80 | Standard | | Enabled | | No | Off | No | |
| 1003 | Optical Smoke ZP730 | 2 | Parking area Bay 82 | Standard | | Enabled | | No | Off | No | |
| 1004 | Optical Smoke ZP730 | 2 | Parking area Bay 83 | Standard | | Enabled | | No | Off | No | |
| 1005 | Optical Smoke ZP730 | 2 | Parking area Bay 85 | Standard | | Enabled | | No | Off | No | |
| 1006 | Optical Smoke ZP730 | 2 | Parking area Bay 86 | Standard | | Enabled | | No | Off | No | |
| 1007 | Optical Smoke ZP730 | 2 | Parking area Bay 88 | Standard | | Enabled | | No | Off | No | |
| 1008 | Optical Smoke ZP730 | 2 | Parking area Bay 90 | Standard | | Enabled | | No | Off | No | |
| 1009 | Optical Smoke ZP730 | 2 | Parking area Bay 92 | Standard | | Enabled | | No | Off | No | |
| 1010 | Optical Smoke ZP730 | 2 | Parking area Bay 94 | Standard | | Enabled | | No | Off | No | |
| 1011 | Optical Smoke ZP730 | 2 | Parking area Bay 95 | Standard | | Enabled | | No | Off | No | |
| 1012 | Optical Smoke ZP730 | 2 | Parking area Bay 96 | Standard | | Enabled | | No | Off | No | |
| 1013 | Optical Smoke ZP730 | 2 | Parking area Bay 62 | Standard | | Enabled | | No | Off | No | |
| 1014 | Optical Smoke ZP730 | 2 | Parking area Entrance | Standard | | Enabled | | No | Off | No | |
| 1015 | Optical Smoke ZP730 | 2 | Parking area Exit | Standard | | Enabled | | No | Off | No | |
| 1016 | Callpoint ZP785 | 2 | Parking area BGU Basement Exit | Standard | | Enabled | | No | Off | No | |
| 1017 | Optical Smoke ZP730 | 2 | Parking area Bay 65 | Standard | | Enabled | | No | Off | No | |
| 1018 | Optical Smoke ZP730 | 2 | Parking area Bay 67 | Standard | | Enabled | | No | Off | No | |
| 1019 | Optical Smoke ZP730 | 2 | Parking area Bay 68 | Standard | | Enabled | | No | Off | No | |
| 1020 | Optical Smoke ZP730 | 2 | Parking area Bay 70 | Standard | | Enabled | | No | Off | No | |
| 1021 | Optical Smoke ZP730 | 2 | Parking area Bay 72 | Standard | | Enabled | | No | Off | No | |
| 1022 | Optical Smoke ZP730 | 2 | Parking area Bay 74 | Standard | | Enabled | | No | Off | No | |
| 1023 | Optical Smoke ZP730 | 2 | Parking area Bay 75 | Standard | | Enabled | | No | Off | No | |
| 1024 | Callpoint ZP785 | 2 | Parking area BGU by Bay 75 | Standard | | Enabled | | No | Off | No | |
| 1025 | Optical Smoke ZP730 | 2 | Parking area Bay 66 | Standard | | Enabled | | No | Off | No | |
| 1026 | Callpoint ZP785 | 10 | Trigger all Sounders | Standard | | Enabled | | No | Off | No | |
| 1027 | Line Sounder ZP755 | | Parking area Sounder by Bay 66 | n/a | | Enabled | | No | Off | No | |
| 1028 | Line Sounder ZP755 | | Parking Area Sounder by Entrance | n/a | | Enabled | | No | Off | No | |
| 1029 | Line Sounder ZP755 | | Parking area Sounder by Bay 75 | n/a | | Enabled | | No | Off | No | |
| 1030 | Address Relay ZP750/A51 | | Basement Parking FANS | n/a | | Enabled | | No | Off | No | |
| 1031 | | | | | | Enabled | | No | Off | No | |
| 1032 | Optical Smoke ZP730 | 3 | Parking area Bay 3 | Standard | | Enabled | | No | Off | No | |

Device Details

Project : SA Tourism

Panel: 1 **Line: 1** (Continued from Page 1)

| Addr | Device Type | Zone | Device Message | Sensitivity | Sensitivity | Disable (Pri) | Disable (Sec) | Base Sounder | AVF | Self Test | Radio Sndr Group |
|------|---------------------|------|-------------------------------|-------------|-------------|---------------|---------------|--------------|-----|-----------|------------------|
| 1033 | Optical Smoke ZP730 | 3 | Parking area Bay 6 | Standard | | Enabled | | No | Off | No | |
| 1034 | Optical Smoke ZP730 | 3 | Parking area Bay 9 | Standard | | Enabled | | No | Off | No | |
| 1035 | Optical Smoke ZP730 | 3 | Basement server room | Standard | | Enabled | | No | Off | No | |
| 1036 | Optical Smoke ZP730 | 3 | Basement UPS Room | Standard | | Enabled | | No | Off | No | |
| 1037 | Optical Smoke ZP730 | 3 | Basement Generator Room | Standard | | Enabled | | No | Off | No | |
| 1038 | Optical Smoke ZP730 | 3 | Parking area Bay 14 | Standard | | Enabled | | No | Off | No | |
| 1039 | Line Sounder ZP755 | 3 | Parking area Bay 8 | n/a | | Enabled | | No | Off | No | |
| 1040 | Callpoint ZP785 | 3 | Basement fire exit stairs BGU | Standard | | Enabled | | No | Off | No | |
| 1041 | Optical Smoke ZP730 | 3 | Parking Bay 18 Sounder | Standard | | Enabled | | No | Off | No | |
| 1042 | Optical Smoke ZP730 | 3 | Parking Bay 21 | Standard | | Enabled | | No | Off | No | |
| 1043 | Optical Smoke ZP730 | 3 | Basement Admin Cleaners Room | Standard | | Enabled | | No | Off | No | |
| 1044 | Optical Smoke ZP730 | 3 | Basement Filing Room | Standard | | Enabled | | No | Off | No | |
| 1045 | Optical Smoke ZP730 | 3 | Parking Bay 22 | Standard | | Enabled | | No | Off | No | |
| 1046 | Line Sounder ZP755 | | Parking Bay 24 Sounder | n/a | | Enabled | | No | Off | No | |
| 1047 | Optical Smoke ZP730 | 3 | Parking Bay 26 | Standard | | Enabled | | No | Off | No | |
| 1048 | Optical Smoke ZP730 | 3 | Parking Bay 28 | Standard | | Enabled | | No | Off | No | |
| 1049 | Optical Smoke ZP730 | 3 | Parking Bay 33 | Standard | | Enabled | | No | Off | No | |
| 1050 | Optical Smoke ZP730 | 3 | Parking Bay 35 | Standard | | Enabled | | No | Off | No | |
| 1051 | Callpoint ZP785 | 3 | Basement Fire exit BGU | Standard | | Enabled | | No | Off | No | |
| 1052 | Optical Smoke ZP730 | 3 | Parking Bay 43 | Standard | | Enabled | | No | Off | No | |
| 1053 | Optical Smoke ZP730 | 3 | Parking Bay 45 | Standard | | Enabled | | No | Off | No | |
| 1054 | Optical Smoke ZP730 | 3 | Parking Bay 48 | Standard | | Enabled | | No | Off | No | |
| 1055 | Optical Smoke ZP730 | 3 | Parking Bay 49 | Standard | | Enabled | | No | Off | No | |
| 1056 | Optical Smoke ZP730 | 3 | Parking Bay 52 | Standard | | Enabled | | No | Off | No | |
| 1057 | Optical Smoke ZP730 | 3 | Parking Bay 55 | Standard | | Enabled | | No | Off | No | |
| 1058 | Optical Smoke ZP730 | 3 | Basement Lift Room | Standard | | Enabled | | No | Off | No | |
| 1059 | Optical Smoke ZP730 | 3 | Parking Bay 59 | Standard | | Enabled | | No | Off | No | |
| 1060 | | | | | | Enabled | | No | Off | No | |
| 1061 | Optical Smoke ZP730 | 3 | Basement Store Room | Standard | | Enabled | | No | Off | No | |
| 1062 | | | | | | Enabled | | No | Off | No | |
| 1063 | | | | | | Enabled | | No | Off | No | |
| 1064 | | | | | | Enabled | | No | Off | No | |
| 1065 | | | | | | Enabled | | No | Off | No | |
| 1066 | | | | | | Enabled | | No | Off | No | |

Device Details

Project : SA Tourism

(Continued from Page 2) ~

| Panel: 1 | | Line: 1 | | | | | | | | | | | |
|----------|-------------|---------|----------------|-------------|-------------|---------------|---------------|--------------|-----|-----------|------------------|--|--|
| Addr | Device Type | Zone | Device Message | Sensitivity | Sensitivity | Disable (Pri) | Disable (Sec) | Base Sounder | AVF | Self Test | Radio Sndr Group | | |
| 1067 | | | | | | Enabled | | No | Off | No | | | |
| 1068 | | | | | | Enabled | | No | Off | No | | | |
| 1069 | | | | | | Enabled | | No | Off | No | | | |
| 1070 | | | | | | Enabled | | No | Off | No | | | |
| 1071 | | | | | | Enabled | | No | Off | No | | | |
| 1072 | | | | | | Enabled | | No | Off | No | | | |
| 1073 | | | | | | Enabled | | No | Off | No | | | |
| 1074 | | | | | | Enabled | | No | Off | No | | | |
| 1075 | | | | | | Enabled | | No | Off | No | | | |
| 1076 | | | | | | Enabled | | No | Off | No | | | |
| 1077 | | | | | | Enabled | | No | Off | No | | | |
| 1078 | | | | | | Enabled | | No | Off | No | | | |
| 1079 | | | | | | Enabled | | No | Off | No | | | |
| 1080 | | | | | | Enabled | | No | Off | No | | | |
| 1081 | | | | | | Enabled | | No | Off | No | | | |
| 1082 | | | | | | Enabled | | No | Off | No | | | |
| 1083 | | | | | | Enabled | | No | Off | No | | | |
| 1084 | | | | | | Enabled | | No | Off | No | | | |
| 1085 | | | | | | Enabled | | No | Off | No | | | |
| 1086 | | | | | | Enabled | | No | Off | No | | | |
| 1087 | | | | | | Enabled | | No | Off | No | | | |
| 1088 | | | | | | Enabled | | No | Off | No | | | |
| 1089 | | | | | | Enabled | | No | Off | No | | | |
| 1090 | | | | | | Enabled | | No | Off | No | | | |
| 1091 | | | | | | Enabled | | No | Off | No | | | |
| 1092 | | | | | | Enabled | | No | Off | No | | | |
| 1093 | | | | | | Enabled | | No | Off | No | | | |
| 1094 | | | | | | Enabled | | No | Off | No | | | |
| 1095 | | | | | | Enabled | | No | Off | No | | | |
| 1096 | | | | | | Enabled | | No | Off | No | | | |
| 1097 | | | | | | Enabled | | No | Off | No | | | |
| 1098 | | | | | | Enabled | | No | Off | No | | | |
| 1099 | | | | | | Enabled | | No | Off | No | | | |
| 1100 | | | | | | Enabled | | No | Off | No | | | |

Device Details

Project : SA Tourism

Panel: 1 **Line: 1** (Continued from Page 3)

| Addr | Device Type | Zone | Device Message | Sensitivity | Disable (Pri) | Disable (Sec) | Base Sounder | AVF | Self Test | Radio Sndr Group |
|------|-------------|------|----------------|-------------|---------------|---------------|--------------|-----|-----------|------------------|
| 1101 | | | | | Enabled | | No | Off | No | |
| 1102 | | | | | Enabled | | No | Off | No | |
| 1103 | | | | | Enabled | | No | Off | No | |
| 1104 | | | | | Enabled | | No | Off | No | |
| 1105 | | | | | Enabled | | No | Off | No | |
| 1106 | | | | | Enabled | | No | Off | No | |
| 1107 | | | | | Enabled | | No | Off | No | |
| 1108 | | | | | Enabled | | No | Off | No | |
| 1109 | | | | | Enabled | | No | Off | No | |
| 1110 | | | | | Enabled | | No | Off | No | |
| 1111 | | | | | Enabled | | No | Off | No | |
| 1112 | | | | | Enabled | | No | Off | No | |
| 1113 | | | | | Enabled | | No | Off | No | |
| 1114 | | | | | Enabled | | No | Off | No | |
| 1115 | | | | | Enabled | | No | Off | No | |
| 1116 | | | | | Enabled | | No | Off | No | |
| 1117 | | | | | Enabled | | No | Off | No | |
| 1118 | | | | | Enabled | | No | Off | No | |
| 1119 | | | | | Enabled | | No | Off | No | |
| 1120 | | | | | Enabled | | No | Off | No | |
| 1121 | | | | | Enabled | | No | Off | No | |
| 1122 | | | | | Enabled | | No | Off | No | |
| 1123 | | | | | Enabled | | No | Off | No | |
| 1124 | | | | | Enabled | | No | Off | No | |
| 1125 | | | | | Enabled | | No | Off | No | |
| 1126 | | | | | Enabled | | No | Off | No | |
| 1127 | | | | | Enabled | | No | Off | No | |

Panel: 1 **Line: 2**

| Addr | Device Type | Zone | Device Message | Sensitivity | Disable (Pri) | Disable (Sec) | Base Sounder | AVF | Self Test | Radio Sndr Group |
|------|---------------------|------|---------------------------------|-------------|---------------|---------------|--------------|-----|-----------|------------------|
| 2001 | Optical Smoke ZP730 | 4 | Ground Floor SE0 Passage | Standard | Enabled | | No | Off | No | |
| 2002 | Optical Smoke ZP730 | 4 | Ground Floor SE0 TAU Board room | Standard | Enabled | | No | Off | No | |
| 2003 | Optical Smoke ZP730 | 4 | Ground Floor SE0 Filing Room | Standard | Enabled | | No | Off | No | |

Device Details

Panel: 1 Line: 2 (Continued from Page 4)

| Addr | Device Type | Zone | Device Message | Sensitivity | Sensitivity | Disable (Pri) | Disable (Sec) | Base Sounder | AVF | Self Test | Radio Sndr Group |
|------|---------------------|------|---|-------------|-------------|---------------|---------------|--------------|-----|-----------|------------------|
| 2004 | Optical Smoke ZP730 | 4 | Ground Floor SE0 Buffalo Board room | Standard | | Enabled | | No | Off | No | |
| 2005 | Optical Smoke ZP730 | 4 | Ground Floor SE0 COS Zareale Office | Standard | | Enabled | | No | Off | No | |
| 2006 | Optical Smoke ZP730 | 4 | Ground Floor SE0 Head CFC & Comp Sec | Standard | | Enabled | | No | Off | No | |
| 2007 | Optical Smoke ZP730 | 4 | Ground Floor SE0 Head CFC & Comp Sec | Standard | | Enabled | | No | Off | No | |
| 2008 | Optical Smoke ZP730 | 4 | Ground Floor SE0 CEO SSA | Standard | | Enabled | | No | Off | No | |
| 2009 | Optical Smoke ZP730 | 4 | Ground Floor SE0 EXEC PA Interim | Standard | | Enabled | | No | Off | No | |
| 2010 | Optical Smoke ZP730 | 4 | Ground Floor SE0 EXEC PA Interim | High | | Enabled | | No | Off | No | |
| 2011 | Line Sounder ZP755 | 4 | Ground Floor SE0 EXEC PA Interim | n/a | | Enabled | | No | Off | No | |
| 2012 | Callpoint ZP785 | 4 | Ground Floor SE0 Staircase BGU | Standard | | Enabled | | No | Off | No | |
| 2013 | Callpoint ZP785 | 4 | Ground Floor SE0 Staircase BGU | Standard | | Enabled | | No | Off | No | |
| 2014 | Optical Smoke ZP730 | 4 | Ground Floor SE0 Store Room | Standard | | Enabled | | No | Off | No | |
| 2015 | Optical Smoke ZP730 | 4 | Ground Floor SE0 FACIL & ICT | Standard | | Enabled | | No | Off | No | |
| 2016 | Optical Smoke ZP730 | 4 | Ground Floor SW0 FACIL & ICT | Standard | | Enabled | | No | Off | No | |
| 2017 | Optical Smoke ZP730 | 4 | Ground Floor SW0 FACIL & ICT | Standard | | Enabled | | No | Off | No | |
| 2018 | Optical Smoke ZP730 | 4 | Ground Floor SW0 FACIL & ICT | Standard | | Enabled | | No | Off | No | |
| 2019 | Optical Smoke ZP730 | 4 | Ground Floor SW0 Payroll Human Capital | Standard | | Enabled | | No | Off | No | |
| 2020 | Optical Smoke ZP730 | 4 | Ground Floor SW0 Human Capital Office | Standard | | Enabled | | No | Off | No | |
| 2021 | Optical Smoke ZP730 | 4 | Ground Floor SW0 Human Capital Area | Standard | | Enabled | | No | Off | No | |
| 2022 | Optical Smoke ZP730 | 4 | Ground Floor SW0 Human Capital Board m | Standard | | Enabled | | No | Off | No | |
| 2023 | Line Sounder ZP755 | 4 | Ground Floor SW0 Sounder | n/a | | Enabled | | No | Off | No | |
| 2024 | Optical Smoke ZP730 | 4 | Ground Floor SW0 Tea Kitchen | Standard | | Enabled | | No | Off | No | |
| 2025 | Optical Smoke ZP730 | 4 | Ground Floor SW0 ICT Board Room | Standard | | Enabled | | No | Off | No | |
| 2026 | | | | | | Enabled | | No | Off | No | |
| 2027 | | | | | | Enabled | | No | Off | No | |
| 2028 | | | | | | Enabled | | No | Off | No | |
| 2029 | | | | | | Enabled | | No | Off | No | |
| 2030 | | | | | | Enabled | | No | Off | No | |
| 2031 | | | | | | Enabled | | No | Off | No | |
| 2032 | Optical Smoke ZP730 | 4 | Ground Floor Waiting Area West | Standard | | Enabled | | No | Off | No | |
| 2033 | Optical Smoke ZP730 | 5 | Ground Floor Boardroom (Ndlouw1) East | Standard | | Enabled | | No | Off | No | |
| 2034 | Optical Smoke ZP730 | 5 | Ground Floor Main Recep Fire Panel East | Standard | | Enabled | | No | Off | No | |
| 2035 | Optical Smoke ZP730 | 5 | Ground Floor Passage East | High | | Enabled | | No | Off | No | |
| 2036 | Optical Smoke ZP730 | 5 | Ground Floor Boardroom (Ndlouw2) East | Standard | | Enabled | | No | Off | No | |
| 2037 | Optical Smoke ZP730 | 5 | Ground Floor Store Room East | Standard | | Enabled | | No | Off | No | |

Device Details

Panel: 1 Line: 2 (Continued from Page 5)

| Addr | Device Type | Zone | Device Message | Sensitivity | Sensitivity | Disable (Pri) | Disable (Sec) | Base Sounder | AVF | Self Test | Radio Sndr Group |
|------|---------------------|------|---|-------------|-------------|---------------|---------------|--------------|-----|-----------|------------------|
| 2038 | Callpoint ZP785 | 5 | Ground Floor Canteen East Fire Exit BGU | Standard | | Enabled | | No | Off | No | |
| 2039 | Optical Smoke ZP730 | 5 | Ground Floor Canteen East | Standard | | Enabled | | No | Off | No | |
| 2040 | Optical Smoke ZP730 | 5 | Ground Floor Kitchen East | Standard | | Enabled | | No | Off | No | |
| 2041 | Optical Smoke ZP730 | 5 | Ground Floor Kitchen East | Standard | | Enabled | | No | Off | No | |
| 2042 | Optical Smoke ZP730 | 5 | Ground Floor Kitchen Store Room East | Standard | | Enabled | | No | Off | No | |
| 2043 | Optical Smoke ZP730 | 5 | Ground Floor Canteen East | Standard | | Enabled | | No | Off | No | |
| 2044 | Optical Smoke ZP730 | 5 | Ground Floor Boardroom (Inigwe) East | Standard | | Enabled | | No | Off | No | |
| 2045 | Optical Smoke ZP730 | 5 | Ground Floor Boardroom (Ithurigwa) East | Standard | | Enabled | | No | Off | No | |
| 2046 | Optical Smoke ZP730 | 5 | Ground Floor Boardroom (Renoster2) East | Standard | | Enabled | | No | Off | No | |
| 2047 | Optical Smoke ZP730 | 5 | Ground Floor Boardroom (Renoster1) East | Standard | | Enabled | | No | Off | No | |
| 2048 | Optical Smoke ZP730 | 5 | Ground Floor Waiting Area East | Standard | | Enabled | | No | Off | No | |
| 2049 | Optical Smoke ZP730 | 5 | Ground Floor Passage East | Standard | | Enabled | | No | Off | No | |
| 2050 | Line Sounder ZP755 | 5 | Ground Floor Passage Sounder East | n/a | | Enabled | | No | Off | No | |
| 2051 | Optical Smoke ZP730 | 6 | First Floor NW1 TGSA Area | Standard | | Enabled | | No | Off | No | |
| 2052 | Line Sounder ZP755 | 6 | First Floor NW1 TGSA Area Sounder | n/a | | Enabled | | No | Off | No | |
| 2053 | Optical Smoke ZP730 | 6 | First Floor NW1 TGSA Area | Standard | | Enabled | | No | Off | No | |
| 2054 | Optical Smoke ZP730 | 6 | First Floor NW1 TGSA Area | Standard | | Enabled | | No | Off | No | |
| 2055 | Optical Smoke ZP730 | 6 | First Floor NW1 TGSA Area | Standard | | Enabled | | No | Off | No | |
| 2056 | Optical Smoke ZP730 | 6 | First Floor NW1 TGSA Area | Standard | | Enabled | | No | Off | No | |
| 2057 | Optical Smoke ZP730 | 6 | First Floor NE1 Finance Area | Standard | | Enabled | | No | Off | No | |
| 2058 | Optical Smoke ZP730 | 6 | First Floor NE1 Finance Area | Standard | | Enabled | | No | Off | No | |
| 2059 | Optical Smoke ZP730 | 6 | First Floor NE1 Finance Area | Standard | | Enabled | | No | Off | No | |
| 2060 | Line Sounder ZP755 | 6 | First Floor NE1 Finance Area Sounder | n/a | | Enabled | | No | Off | No | |
| 2061 | Optical Smoke ZP730 | 6 | First Floor NE1 Finance Area | Standard | | Enabled | | No | Off | No | |
| 2062 | Optical Smoke ZP730 | 6 | First Floor NE1 Finance Area | Standard | | Enabled | | No | Off | No | |
| 2063 | Optical Smoke ZP730 | 6 | First Floor NE1 Finance Area | Standard | | Enabled | | No | Off | No | |
| 2064 | Callpoint ZP785 | 6 | First Floor NE1 Staircase BGU | Standard | | Enabled | | No | Off | No | |
| 2065 | Optical Smoke ZP730 | 6 | First Floor NE1 Internal Audit Area | Standard | | Enabled | | No | Off | No | |
| 2066 | Optical Smoke ZP730 | 6 | First Floor NE1 Internal Audit Area | Standard | | Enabled | | No | Off | No | |
| 2067 | Optical Smoke ZP730 | 6 | First Floor NE1 Internal Audit 8 Seater | Standard | | Enabled | | No | Off | No | |
| 2068 | | | | | | Enabled | | No | Off | No | |
| 2069 | | | | | | Enabled | | No | Off | No | |
| 2070 | | | | | | Enabled | | No | Off | No | |
| 2071 | | | | | | Enabled | | No | Off | No | |

Device Details

Panel: 1 Line: 2 (Continued from Page 6)

| Addr | Device Type | Zone | Device Message | Sensitivity | Sensitivity | Disable (Pri) | Disable (Sec) | Base Sounder | AVF | Self Test | Radio Sndr Group |
|------|---------------------|------|-----------------------------------|-------------|-------------|---------------|---------------|--------------|-----|-----------|------------------|
| 2072 | | | | | | Enabled | | No | Off | No | |
| 2073 | | | | | | Enabled | | No | Off | No | |
| 2074 | | | | | | Enabled | | No | Off | No | |
| 2075 | | | | | | Enabled | | No | Off | No | |
| 2076 | | | | | | Enabled | | No | Off | No | |
| 2077 | | | | | | Enabled | | No | Off | No | |
| 2078 | Optical Smoke ZP730 | 7 | First Floor Passage | Standard | | Enabled | | No | Off | No | |
| 2079 | Optical Smoke ZP730 | 7 | First Floor Lobby Filing Room | High | | Enabled | | No | Off | No | |
| 2080 | Optical Smoke ZP730 | 7 | First Floor SW1 NCB Area | High | | Enabled | | No | Off | No | |
| 2081 | Optical Smoke ZP730 | 7 | First Floor SW1 NCB Area | High | | Enabled | | No | Off | No | |
| 2082 | Optical Smoke ZP730 | 7 | First Floor SW1 NCB Area | High | | Enabled | | No | Off | No | |
| 2083 | Optical Smoke ZP730 | 7 | First Floor SW1 NCB Area 4 Seater | High | | Enabled | | No | Off | No | |
| 2084 | Line Sounder ZP755 | 7 | First Floor SW1 NCB Area Sounder | n/a | | Enabled | | No | Off | No | |
| 2085 | Optical Smoke ZP730 | 7 | First Floor SW1 Tourism Execution | High | | Enabled | | No | Off | No | |
| 2086 | Optical Smoke ZP730 | 7 | First Floor SE1 Tourism Execution | High | | Enabled | | No | Off | No | |
| 2087 | Optical Smoke ZP730 | 7 | First Floor SE1 Tourism Execution | High | | Enabled | | No | Off | No | |
| 2088 | Optical Smoke ZP730 | 7 | First Floor SE1 Strategy | High | | Enabled | | No | Off | No | |
| 2089 | Optical Smoke ZP730 | 7 | First Floor SE1 Strategy | High | | Enabled | | No | Off | No | |
| 2090 | Callpoint ZP785 | 7 | First Floor SE1 Staircase BGU | High | | Enabled | | No | Off | No | |
| 2091 | Line Sounder ZP754 | 7 | First Floor SE1 Strategy Sounder | n/a | | Enabled | | No | Off | No | |
| 2092 | Optical Smoke ZP730 | 7 | First Floor SE1 Tourism Marketing | High | | Enabled | | No | Off | No | |
| 2093 | Optical Smoke ZP730 | 7 | First Floor SE1 Tourism Marketing | High | | Enabled | | No | Off | No | |
| 2094 | Optical Smoke ZP730 | 7 | First Floor SE1 Tourism Marketing | High | | Enabled | | No | Off | No | |
| 2095 | Optical Smoke ZP730 | 7 | First Floor SE1 Strategy | High | | Enabled | | No | Off | No | |
| 2096 | | | | | | Enabled | | No | Off | No | |
| 2097 | | | | | | Enabled | | No | Off | No | |
| 2098 | | | | | | Enabled | | No | Off | No | |
| 2099 | | | | | | Enabled | | No | Off | No | |
| 2100 | | | | | | Enabled | | No | Off | No | |
| 2101 | | | | | | Enabled | | No | Off | No | |
| 2102 | | | | | | Enabled | | No | Off | No | |
| 2103 | | | | | | Enabled | | No | Off | No | |
| 2104 | | | | | | Enabled | | No | Off | No | |
| 2105 | | | | | | Enabled | | No | Off | No | |

Device Details

Panel: 1 Line: 2 (Continued from Page 7)

| Addr | Device Type | Zone | Device Message | Sensitivity | Sensitivity | Disable (Pri) | Disable (Sec) | Base Sounder | AVF | Self Test | Radio Snr Group |
|------|-------------|------|----------------|-------------|-------------|---------------|---------------|--------------|-----|-----------|-----------------|
| 2106 | | | | | | Enabled | | No | Off | No | |
| 2107 | | | | | | Enabled | | No | Off | No | |
| 2108 | | | | | | Enabled | | No | Off | No | |
| 2109 | | | | | | Enabled | | No | Off | No | |
| 2110 | | | | | | Enabled | | No | Off | No | |
| 2111 | | | | | | Enabled | | No | Off | No | |
| 2112 | | | | | | Enabled | | No | Off | No | |
| 2113 | | | | | | Enabled | | No | Off | No | |
| 2114 | | | | | | Enabled | | No | Off | No | |
| 2115 | | | | | | Enabled | | No | Off | No | |
| 2116 | | | | | | Enabled | | No | Off | No | |
| 2117 | | | | | | Enabled | | No | Off | No | |
| 2118 | | | | | | Enabled | | No | Off | No | |
| 2119 | | | | | | Enabled | | No | Off | No | |
| 2120 | | | | | | Enabled | | No | Off | No | |
| 2121 | | | | | | Enabled | | No | Off | No | |
| 2122 | | | | | | Enabled | | No | Off | No | |
| 2123 | | | | | | Enabled | | No | Off | No | |
| 2124 | | | | | | Enabled | | No | Off | No | |
| 2125 | | | | | | Enabled | | No | Off | No | |
| 2126 | | | | | | Enabled | | No | Off | No | |
| 2127 | | | | | | Enabled | | No | Off | No | |

I/O Mapping by Output

Panel: 1 Name: SA TOURISM Type: ZP3 EN54 2 Loop/128 Zone

| Output Details | | | | Output Properties | | | | | | Input Details | | | | Input Properties | | | | |
|----------------|--------------|----------------|-------------------------|-------------------|-------------|-----------|--------------|--------------|------------------|---------------|----------------|-------|--------------|------------------|---------------|-------------------|---------|--------|
| Target Panel | Output Group | Output Address | Output Device Type | Output Mode | Output Type | Day Delay | Normal State | Common Alarm | Output Reacivate | Delay Time | Output Disable | Label | Source Panel | Input Group | Input Address | Input Device Type | Trigger | Action |
| 1 | Line 1 | 027 | Line Sounder ZP755 | SK-SL | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | | 1 | Zone | 002 | Active | Steady | |
| 1 | Line 1 | 027 | Line Sounder ZP755 | | Standard | | | | | | | | 1 | Zone | 003 | Active | Steady | |
| 1 | Line 1 | 027 | Line Sounder ZP755 | | Standard | | | | | | | | 1 | Zone | 010 | Active | Steady | |
| 1 | Line 1 | 028 | Line Sounder ZP755 | SK-SL | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | | 1 | Zone | 002 | Active | Steady | |
| 1 | Line 1 | 028 | Line Sounder ZP755 | | Standard | | | | | | | | 1 | Zone | 003 | Active | Steady | |
| 1 | Line 1 | 028 | Line Sounder ZP755 | | Standard | | | | | | | | 1 | Zone | 010 | Active | Steady | |
| 1 | Line 1 | 029 | Line Sounder ZP755 | SK-SL | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | | 1 | Zone | 002 | Active | Steady | |
| 1 | Line 1 | 029 | Line Sounder ZP755 | | Standard | | | | | | | | 1 | Zone | 003 | Active | Steady | |
| 1 | Line 1 | 029 | Line Sounder ZP755 | | Standard | | | | | | | | 1 | Zone | 010 | Active | Steady | |
| 1 | Line 1 | 030 | Address Relay ZP750/A51 | DK-NS | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | | 1 | Zone | 002 | Active | Steady | |
| 1 | Line 1 | 030 | Address Relay ZP750/A51 | | Standard | | | | | | | | 1 | Zone | 003 | Active | Steady | |
| 1 | Line 1 | 039 | Line Sounder ZP755 | SK-SL | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | | 1 | Zone | 002 | Active | Steady | |
| 1 | Line 1 | 039 | Line Sounder ZP755 | | Standard | | | | | | | | 1 | Zone | 003 | Active | Steady | |
| 1 | Line 1 | 039 | Line Sounder ZP755 | | Standard | | | | | | | | 1 | Zone | 010 | Active | Steady | |
| 1 | Line 1 | 046 | Line Sounder ZP755 | SK-SL | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | | 1 | Zone | 002 | Active | Steady | |
| 1 | Line 1 | 046 | Line Sounder ZP755 | | Standard | | | | | | | | 1 | Zone | 003 | Active | Steady | |
| 1 | Line 1 | 046 | Line Sounder ZP755 | | Standard | | | | | | | | 1 | Zone | 010 | Active | Steady | |
| 1 | Line 2 | 011 | Line Sounder ZP755 | SK-NS | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | | 1 | Zone | 004 | Active | Steady | |
| 1 | Line 2 | 011 | Line Sounder ZP755 | | Standard | | | | | | | | 1 | Zone | 010 | Active | Steady | |
| 1 | Line 2 | 023 | Line Sounder ZP755 | SK-NS | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | | 1 | Zone | 004 | Active | Steady | |
| 1 | Line 2 | 023 | Line Sounder ZP755 | | Standard | | | | | | | | 1 | Zone | 010 | Active | Steady | |
| 1 | Line 2 | 050 | Line Sounder ZP755 | SK-SL | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | | 1 | Zone | 005 | Active | Steady | |
| 1 | Line 2 | 050 | Line Sounder ZP755 | | Standard | | | | | | | | 1 | Zone | 010 | Active | Steady | |
| 1 | Line 2 | 052 | Line Sounder ZP755 | SK-NS | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | | 1 | Zone | 006 | Active | Steady | |
| 1 | Line 2 | 052 | Line Sounder ZP755 | | Standard | | | | | | | | 1 | Zone | 010 | Active | Steady | |
| 1 | Line 2 | 060 | Line Sounder ZP755 | SK-NS | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | | 1 | Zone | 006 | Active | Steady | |
| 1 | Line 2 | 060 | Line Sounder ZP755 | | Standard | | | | | | | | 1 | Zone | 010 | Active | Steady | |
| 1 | Line 2 | 084 | Line Sounder ZP755 | SK-NS | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | | 1 | Zone | 007 | Active | Steady | |
| 1 | Line 2 | 084 | Line Sounder ZP755 | | Standard | | | | | | | | 1 | Zone | 010 | Active | Steady | |
| 1 | Line 2 | 091 | Line Sounder ZP754 | SK-NS | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | | 1 | Zone | 007 | Active | Steady | |

I/O Mapping by Output

Project : SA Tourism

Panel: 1 Name: SA TOURISM (Continued from Page 1) Type: ZP3 EN54 2 Loop/128 Zone

| Output Details | | Output Properties | | | | Input Details | | | | Input Properties | | | | | | | | |
|----------------|--------------|-------------------|--------------------|-------------|-------------|---------------|--------------|--------------|-------------------|------------------|----------------|-------|--------------|-------------|---------------|-------------------|---------|--------|
| Target Panel | Output Group | Output Address | Output Device Type | Output Mode | Output Type | Day Delay | Normal State | Common Alarm | Output Reactivate | Delay Time | Output Disable | Label | Source Panel | Input Group | Input Address | Input Device Type | Trigger | Action |
| 1 | Line 2 | 091 | Line Sounder ZP754 | | Standard | | | | | | | | 1 | Zone | 010 | | Active | Steady |

I/O Mapping by Input

Panel: 1 Name: SA TOURISM

Type: ZP3 EN54 2 Loop/128 Zone

| Input Details | | | | Input Properties | | | Output Details | | | Output Properties | | | | | | | | |
|---------------|-------------|---------------|-------------------|------------------|--------|--------------|----------------|----------------|-------------------------|-------------------|-------------|-----------|--------------|--------------|-------------------|------------|----------------|-------|
| Source Panel | Input Group | Input Address | Input Device Type | Trigger | Action | Target Panel | Output Group | Output Address | Output Device Type | Output Mode | Output Type | Day Delay | Normal State | Common Alarm | Output Reactivate | Delay Time | Output Disable | Label |
| 1 | Zone | 2 | | Active | Steady | 1 | Line 1 | 27 | Line Sounder ZP755 | SK-SL | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 2 | | Active | Steady | 1 | Line 1 | 28 | Line Sounder ZP755 | SK-SL | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 2 | | Active | Steady | 1 | Line 1 | 29 | Line Sounder ZP755 | SK-SL | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 2 | | Active | Steady | 1 | Line 1 | 30 | Address Relay ZP750/A51 | DK-NS | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 2 | | Active | Steady | 1 | Line 1 | 39 | Line Sounder ZP755 | SK-SL | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 2 | | Active | Steady | 1 | Line 1 | 46 | Line Sounder ZP755 | SK-SL | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 3 | | Active | Steady | 1 | Line 1 | 27 | Line Sounder ZP755 | SK-SL | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 3 | | Active | Steady | 1 | Line 1 | 28 | Line Sounder ZP755 | SK-SL | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 3 | | Active | Steady | 1 | Line 1 | 29 | Line Sounder ZP755 | SK-SL | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 3 | | Active | Steady | 1 | Line 1 | 30 | Address Relay ZP750/A51 | DK-NS | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 3 | | Active | Steady | 1 | Line 1 | 39 | Line Sounder ZP755 | SK-SL | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 3 | | Active | Steady | 1 | Line 1 | 46 | Line Sounder ZP755 | SK-SL | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 4 | | Active | Steady | 1 | Line 2 | 11 | Line Sounder ZP755 | SK-NS | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 4 | | Active | Steady | 1 | Line 2 | 23 | Line Sounder ZP755 | SK-NS | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 5 | | Active | Steady | 1 | Line 2 | 50 | Line Sounder ZP755 | SK-SL | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 6 | | Active | Steady | 1 | Line 2 | 52 | Line Sounder ZP755 | SK-NS | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 6 | | Active | Steady | 1 | Line 2 | 60 | Line Sounder ZP755 | SK-NS | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 7 | | Active | Steady | 1 | Line 2 | 84 | Line Sounder ZP755 | SK-NS | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 7 | | Active | Steady | 1 | Line 2 | 91 | Line Sounder ZP754 | SK-NS | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 10 | | Active | Steady | 1 | Line 1 | 27 | Line Sounder ZP755 | SK-SL | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 10 | | Active | Steady | 1 | Line 1 | 28 | Line Sounder ZP755 | SK-SL | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 10 | | Active | Steady | 1 | Line 1 | 29 | Line Sounder ZP755 | SK-SL | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 10 | | Active | Steady | 1 | Line 1 | 39 | Line Sounder ZP755 | SK-SL | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 10 | | Active | Steady | 1 | Line 1 | 46 | Line Sounder ZP755 | SK-SL | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 10 | | Active | Steady | 1 | Line 2 | 11 | Line Sounder ZP755 | SK-NS | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 10 | | Active | Steady | 1 | Line 2 | 23 | Line Sounder ZP755 | SK-NS | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |

I/O Mapping by Input

Project : SA Tourism

(Continued from Page 1)

Type: ZP3 EN54 2 Loop/128 Zone

Panel: 1 Name: SA TOURISM

| Input Details | | | Input Properties | | | Output Details | | | Output Properties | | | | | | | | | |
|---------------|-------------|---------------|-------------------|---------|--------|----------------|--------------|----------------|--------------------|-------------|-------------|-----------|--------------|--------------|-------------------|------------|----------------|-------|
| Source Panel | Input Group | Input Address | Input Device Type | Trigger | Action | Target Panel | Output Group | Output Address | Output Device Type | Output Mode | Output Type | Day Delay | Normal State | Common Alarm | Output Reactivate | Delay Time | Output Disable | Label |
| 1 | Zone | 10 | | Active | Steady | 1 | Line 2 | 50 | Line Sounder ZP755 | SK-SL | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 10 | | Active | Steady | 1 | Line 2 | 52 | Line Sounder ZP755 | SK-NS | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 10 | | Active | Steady | 1 | Line 2 | 60 | Line Sounder ZP755 | SK-NS | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 10 | | Active | Steady | 1 | Line 2 | 84 | Line Sounder ZP755 | SK-NS | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |
| 1 | Zone | 10 | | Active | Steady | 1 | Line 2 | 91 | Line Sounder ZP754 | SK-NS | Standard | No | Off | Own Inputs | Any Fire | 0 | Enabled | |